


| | | | |
|-------------------------|--|----------------------|----------------|
| Business: | Construction Services | | ALERT |
| Title: | Pallet Stackers | Reference No: | CCS184 |
| Issue Date: | 31 st March 2016 | Issued By: | Bill Stevenson |
| Type of Alert: | Health & Safety | | |
| Subject: | Overturning of manual handling equipment | | |
| Who is affected: | All projects – Supply chain – predominantly brick/blockwork contractors. | | |



| | |
|--|--|
| Details: | Over recent months we have had 2 events on Carillion Building projects where pallet stackers (similar to that shown in the middle picture) have overturned. Both instances occurred when pallets of blocks were being lifted onto scaffolding. |
| Action Required: | This type of pallet stacker is designed for use within a warehouse environment and their use on Carillion Construction sites as a lifting appliance is to cease with immediate effect. |
| Further Information: | N/A |
| Original Source: | Carillion Building |
| Method for confirming that actions have been taken: | Communicated and records retained in project files |

| | |
|----------------------------|---------------------------------|
| Local Action Taken: | << Contract Head to complete >> |
|----------------------------|---------------------------------|